

**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

Arthur Rann School

515 South Eighth Avenue
Galloway, NJ 08205

Results of Lead Analysis


Date & Time Sampled: 05/02/2017 05:03 - 06:10

Date & Time Analyzed: 05/03/2017 16:46 - 22:03

Date & Time Analyzed: 05/05/2017 11:11 - 12:48

Sample Location	Sample Result	Action Level
Field Reagent Blank (FRB)	<2.00	15.5
AR-IM1	<2.00	15.5
AR-SK8	3.90	15.5
AR-SK9	3.90	15.5
AR-WF3	9.46	15.5
AR-WC4	<2.00	15.5
AR-SK6	<2.00	15.5
AR-SK7	2.86	15.5
AR-WC2	<2.00	15.5
AR-WC3	<2.00	15.5
AR-SK5	<2.00	15.5
AR-SK4	<2.00	15.5
AR-SK3	<2.00	15.5
AR-WC1	<2.00	15.5
AR-SK2	<2.00	15.5
AR-WF2	2.79	15.5
AR-SK1	5.97	15.5
AR-WF1	<2.00	15.5
AR-SK10	<2.00	15.5
AR-SK12	2.18	15.5

Units - ug/L = ppb



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

Arthur Rann School

515 South Eighth Avenue
Galloway, NJ 08205

Results of Lead Analysis


Date & Time Sampled: 05/02/2017 05:03 - 06:10

Date & Time Analyzed: 05/03/2017 16:46 - 22:03

Date & Time Analyzed: 05/05/2017 11:11 - 12:48

Sample Location	Sample Result	Action Level
AR-WF11	3.02	15.5
AR-SK22	<2.00	15.5
AR-SK23	52.7	15.5
AR-SK12	<2.00	15.5
AR-SK11	4.73	15.5
AR-WF4	<2.00	15.5
AR-SK14	2.05	15.5
AR-WF5	<2.00	15.5
AR-SK15	<2.00	15.5
AR-WF6	<2.00	15.5
AR-SK16	<2.00	15.5
AR-WF7	3.84	15.5
AR-SK17	3.63	15.5
AR-WF8	3.77	15.5
AR-IM1	<2.00	15.5
AR-SK19	<2.00	15.5
AR-SK20	<2.00	15.5
AR-SK21	35.0	15.5
AR-WC9	3.88	15.5
AR-WC10	2.07	15.5

Units - ug/L = ppb



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

Arthur Rann School

515 South Eighth Avenue
Galloway, NJ 08205

Results of Lead Analysis

Date & Time Sampled: 05/02/2017 05:03 - 06:10

Date & Time Analyzed: 05/03/2017 16:46 - 22:03

Date & Time Analyzed: 05/05/2017 11:11 - 12:48


Sample Location	Sample Result	Action Level
AR-WC11	2.64	15.5
AR-WC12	<2.00	15.5
AR-WC13	<2.00	15.5
AR-WC6	<2.00	15.5
AR-WC7	<2.00	15.5
AR-WC8	<2.00	15.5
AR-WF9	53.1	15.5
AR-SK18	10.8	15.5
AR-WF10	35.0	15.5

Units - ug/L = ppb

Action Level: The concentration of lead which determines whether some form of corrective action may be necessary.

QA/QC: Laboratory Fortified Blank (LFB) meets criteria of plus or minus 15% recovery.

Field Reagent Blank (FRB) concentration equals <2.00 ug/L.


Mark J. Riether, Laboratory Director

5/16/17
Date

CHAIN OF CUSTODY RECORD

Customer: Galloway Township Public Schools
Contact: Steve Bolli
Address: 101 South Reeds Road
 Galloway, NJ 08205
Phone:
Office: (609) 748-1250 x 5121

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
 www.sjwatertest.com
 NJ DEP Certification #08006



Lab ID#	Sample Location	Collection Date	Time	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
P6A716	Arthur Mann	5/2/17	503	D	1 x 250	HNO3*	First Draw Lead	
P6A717	IML		505	D	1 x 250	HNO3*	First Draw Lead	
P6A718	SK8		507	D	1 x 250	HNO3*	First Draw Lead	
P6A719	SK9		510	D	1 x 250	HNO3*	First Draw Lead	
P6A720	WF3		511	D	1 x 250	HNO3*	First Draw Lead	
P6A721	WCH		513	D	1 x 250	HNO3*	First Draw Lead	
P6A722	SK6		515	D	1 x 250	HNO3*	First Draw Lead	
P6A723	SK7		517	D	1 x 250	HNO3*	First Draw Lead	
P6A724	WLC2		520	D	1 x 250	HNO3*	First Draw Lead	
P6A725	WLC3		521	D	1 x 250	HNO3*	First Draw Lead	

MATRIX ABBREVIATIONS: DIDRINKING WATER AQUEOUS SISOIL SL/SLUDGE GW/GROUND WATER SW/SURFACE WATER WW/WASTE WATER

Turnaround Time ___ SJWT Standard is 10-20 work days ___ Rush turnaround available upon request and lab approval _____	Report Format ___ Standard ___ NJ DEP Reduced Deliverables ___ NJ DEP Full Deliverables ___ Electronic Data Deliverables ___ PWTA Format	Comments/Special Instructions * HNO3 preserved upon receipt at laboratory	Cooler Temp °C
Yes <input type="checkbox"/> No <input type="checkbox"/>			

Sampled by: Justin M. Lillo (Print)

Sampled by/Relinquished by: Justin M. Lillo (Signature) Date: 5/2/17 Time: 700

Relinquished by: Steve Bolli (Signature) Date: 5/2/17 Time: 0700


Relinquished by: (Signature) Date: Date Time: Time

Relinquished by: (Signature) Date: Date Time: Time

CHAIN OF CUSTODY RECORD

Customer: Galloway Township Public Schools
Contact: Steve Bolli
Address: 101 South Reeds Road
 Galloway, NJ 08205
Phone:
Office: (609) 748-1250 x 5121

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
 www.sjwaterfest.com
 NJ DEP Certification #08006



Lab ID#	Sample Location	Collection Date	Time	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
PG4726	Arthur Bann	5/21/17	523	D	1 x 250	HNO3*	First Draw Lead	
PG4727	SK4		524	D	1 x 250	HNO3*	First Draw Lead	
PG4728	SK3		526	D	1 x 250	HNO3*	First Draw Lead	
PG4729	WCL		527	D	1 x 250	HNO3*	First Draw Lead	
PG4730	SK2		528	D	1 x 250	HNO3*	First Draw Lead	
PG4731	WF2		529	D	1 x 250	HNO3*	First Draw Lead	
PG4732	SK4		530	D	1 x 250	HNO3*	First Draw Lead	
PG4733	WF1		531	D	1 x 250	HNO3*	First Draw Lead	
PG4734	SK10		533	D	1 x 250	HNO3*	First Draw Lead	
PG4735	SK12		534	D	1 x 250	HNO3*	First Draw Lead	

MATRIX ABBREVIATIONS: DIDRINKING WATER AQUEOUS SISOIL SL/SLUDGE GW/GROUND WATER SW/SURFACE WATER WW/WASTE WATER

Turnaround Time	Standard	Report Format	Comments/Special Instructions	Cooler Temp
	<input type="checkbox"/> NJ DEP Reduced Deliverables <input type="checkbox"/> NJ DEP Full Deliverables <input type="checkbox"/> Electronic Data Deliverables <input type="checkbox"/> PWTA Format			
SJWT Standard is 10-20 work days Rush turnaround available upon request and lab approval _____				

Sampled by: *Justin Mille*

Sampled by/Relinquished by: *Justin Mille* Date: *5/21/17* Time: *700*

Relinquished by: _____ Date: _____ Time: _____

Relinquished by: _____ Date: _____ Time: _____

CHAIN OF CUSTODY RECORD

Customer: Galloway Township Public Schools
Contact: Steve Bolli
Address: 101 South Reeds Road
 Galloway, NJ 08205
Phone:
Office: (609) 748-1250 x 5121

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
 www.sjwaterest.com
 NJ DEP Certification #08006



Lab ID#	Sample Location	Collection Date	Time	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
R6A736	Arthw Pond	5/2/17	535	D	1 x 250	HNO3*	First Draw Lead	
R6A737	SK22		536	D	1 x 250	HNO3*	First Draw Lead	
R6A738	SK23		537	D	1 x 250	HNO3*	First Draw Lead	
R6A739	SK13		538	D	1 x 250	HNO3*	First Draw Lead	
R6A740	SK11		539	D	1 x 250	HNO3*	First Draw Lead	
R6A741	WF4		540	D	1 x 250	HNO3*	First Draw Lead	
R6A742	SK14		541	D	1 x 250	HNO3*	First Draw Lead	
R6A743	WF5		542	D	1 x 250	HNO3*	First Draw Lead	
R6A744	SK15		543	D	1 x 250	HNO3*	First Draw Lead	
R6A745	WF6		544	D	1 x 250	HNO3*	First Draw Lead	

MATRIX ABBREVIATIONS: DIDRINKING WATER AQUEOUS SISOIL SL/SLUDGE GW/GROUND WATER SWS/SURFACE WATER WW/WASTE WATER

Turnaround Time SJWT Standard is 10-20 work days Rush turnaround available upon request and lab approval _____	Report Format Standard ___ NJ DEP Reduced Deliverables ___ NJ DEP Full Deliverables ___ Electronic Data Deliverables ___ PWTA Format	Comments/Special Instructions * HNO3 preserved upon receipt at laboratory	Cooler Temp °C
			Yes No

Sampled by: *Justin Milano*
 Sampled by/Relinquished by: *Justin Milano*
 Relinquished by:
 Relinquished by:

Received by: <i>[Signature]</i>	Date: 5/2/17	Time: 0700
Received by:	Date:	Time:
Received by:	Date:	Time:

CHAIN OF CUSTODY RECORD

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
 www.sjwatertest.com
 NJ DEP Certification #08006

Customer: Galloway Township Public Schools
Contact: Steve Bolli
Address: 101 South Reeds Road
 Galloway, NJ 08205
Phone:
Office: (609) 748-1250 x 5121

Lab ID#	Sample Location	Collection Date	Time	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
PG4746	Arthur Hann	5/2/17	545	D	1 x 250	HNO3*	First Draw Lead	
PG4747	WF7		546	D	1 x 250	HNO3*	First Draw Lead	
PG4748	SK17		547	D	1 x 250	HNO3*	First Draw Lead	
PG4749	WF8		548	D	1 x 250	HNO3*	First Draw Lead	
PG4750	IMA		550	D	1 x 250	HNO3*	First Draw Lead	
PG4751	SK19		551	D	1 x 250	HNO3*	First Draw Lead	
PG4752	SK20		552	D	1 x 250	HNO3*	First Draw Lead	
PG4753	SK21		555	D	1 x 250	HNO3*	First Draw Lead	
PG4754	WLG9		556	D	1 x 250	HNO3*	First Draw Lead	
PG4755	WLG10		557	D	1 x 250	HNO3*	First Draw Lead	

MATRIX ABBREVIATIONS: DIDRINKING WATER AWAQUEOUS SISOIL SL/SLUDGE GWGROUND WATER SWSURFACE WATER WWWASTE WATER

Turnaround Time	Standard	Report Format	Comments/Special Instructions	Cooler Temp
	<input type="checkbox"/> SJWT Standard is 10-20 work days <input type="checkbox"/> Rush turnaround available upon request and lab approval _____	<input type="checkbox"/> Standard <input type="checkbox"/> NJ DEP Reduced Deliverables <input type="checkbox"/> NJ DEP Full Deliverables <input type="checkbox"/> Electronic Data Deliverables <input type="checkbox"/> PWTA Format		

Sampled by: *Justin Milla*

Sampled by/Relinquished by: *Justin Milla* Date: *5/2/17* Time: *700*

Relinquished by: _____ Date: _____ Time: _____

Relinquished by: _____ Date: _____ Time: _____

Relinquished by: _____ Date: _____ Time: _____

CHAIN OF CUSTODY RECORD

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
 www.sjwatertest.com
 NJ DEP Certification #08006

Customer: Galloway Township Public Schools
Contact: Steve Bolli
Address: 101 South Reeds Road
 Galloway, NJ 08205
Phone:
Office: Fax: (609) 748-1250 x 5121

Lab ID#	Sample Location	Date	Collection Time	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
PLA756	Ashur hana	5/2/17	558	D	1 x 250	HNO3*	First Draw Lead	
PLA757	WC12		600	D	1 x 250	HNO3*	First Draw Lead	
PLA758	WC13		601	D	1 x 250	HNO3*	First Draw Lead	
PLA759	WC6		603	D	1 x 250	HNO3*	First Draw Lead	
PLA760	WC7		604	D	1 x 250	HNO3*	First Draw Lead	
PLA761	WC8		605	D	1 x 250	HNO3*	First Draw Lead	
PLA762	WFA		607	D	1 x 250	HNO3*	First Draw Lead	
PLA763	SK18		608	D	1 x 250	HNO3*	First Draw Lead	
PLA764	WF10		610	D	1 x 250	HNO3*	First Draw Lead	

MATRIX ABBREVIATIONS: DIDRINKING WATER AWAQUEOUS SISOIL SLISLUDGE GWGROUND WATER SWSURFACE WATER WWWASTE WATER

Turnaround Time	Standard	Report Format	Comments/Special Instructions	Cooler Temp
	<input type="checkbox"/> SJWT Standard is 10-20 work days <input type="checkbox"/> Rush turnaround available upon request and lab approval _____	<input type="checkbox"/> Standard <input type="checkbox"/> NJ DEP Reduced Deliverables <input type="checkbox"/> NJ DEP Full Deliverables <input type="checkbox"/> Electronic Data Deliverables <input type="checkbox"/> PWTA Format		

Sampled by: *Justin Milla*

Sampled by/Relinquished by: *Justin Milla* Date: *5/2/17* Time: *700*

Relinquished by: _____ Date: _____ Time: _____

Relinquished by: _____ Date: _____ Time: _____

Arthur Rann School
Excel Template for Lead Results

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O
Field ID	Flushed Y/N	Laboratory Sample ID	Laboratory Name	Lab Certification ID	Date Sampled	Time Sampled	Analytical Method	Date of Analysis	Time of Analysis	Concentration in ug/L	Reporting Limit (ug/L)	Dilution Factor	Digested (Y/N)	Qualifier
1														
2		P64716	South Jersey Water Test, LLC	08006	5/2/2017	5:03	SM3113B	5/3/2017	16:46	<2.00	<2.00	1	N	
3		P64717	South Jersey Water Test, LLC	08006	5/2/2017	5:05	SM3113B	5/3/2017	17:19	<2.00	<2.00	1	N	
4		P64718	South Jersey Water Test, LLC	08006	5/2/2017	5:07	SM3113B	5/3/2017	17:25	3.90	<2.00	1	N	
5		P64719	South Jersey Water Test, LLC	08006	5/2/2017	5:10	SM3113B	5/3/2017	17:25	3.90	<2.00	1	N	
6		P64720	South Jersey Water Test, LLC	08006	5/2/2017	5:11	SM3113B	5/3/2017	17:38	9.46	<2.00	1	N	
7		P64721	South Jersey Water Test, LLC	08006	5/2/2017	5:13	SM3113B	5/3/2017	17:45	<2.00	<2.00	1	N	
8		P64722	South Jersey Water Test, LLC	08006	5/2/2017	5:15	SM3113B	5/3/2017	17:52	<2.00	<2.00	1	N	
9		P64723	South Jersey Water Test, LLC	08006	5/2/2017	5:17	SM3113B	5/3/2017	17:58	2.86	<2.00	1	N	
10		P64724	South Jersey Water Test, LLC	08006	5/2/2017	5:20	SM3113B	5/3/2017	18:05	<2.00	<2.00	1	N	
11		P64725	South Jersey Water Test, LLC	08006	5/2/2017	5:21	SM3113B	5/3/2017	18:25	<2.00	<2.00	1	N	
12		P64726	South Jersey Water Test, LLC	08006	5/2/2017	2:23	SM3113B	5/3/2017	18:32	<2.00	<2.00	1	N	
13		P64727	South Jersey Water Test, LLC	08006	5/2/2017	5:24	SM3113B	5/3/2017	18:38	<2.00	<2.00	1	N	
14		P64728	South Jersey Water Test, LLC	08006	5/2/2017	5:26	SM3113B	5/3/2017	18:45	<2.00	<2.00	1	N	
15		P64729	South Jersey Water Test, LLC	08006	5/2/2017	5:27	SM3113B	5/3/2017	18:51	<2.00	<2.00	1	N	
16		P64730	South Jersey Water Test, LLC	08006	5/2/2017	5:28	SM3113B	5/3/2017	18:58	<2.00	<2.00	1	N	
17		P64731	South Jersey Water Test, LLC	08006	5/2/2017	5:29	SM3113B	5/3/2017	19:05	2.79	<2.00	1	N	
18		P64732	South Jersey Water Test, LLC	08006	5/2/2017	5:30	SM3113B	5/3/2017	19:11	5.97	<2.00	1	N	
19		P64733	South Jersey Water Test, LLC	08006	5/2/2017	5:31	SM3113B	5/3/2017	19:18	<2.00	<2.00	1	N	
20		P64734	South Jersey Water Test, LLC	08006	5/2/2017	5:33	SM3113B	5/3/2017	19:24	<2.00	<2.00	1	N	
21		P64735	South Jersey Water Test, LLC	08006	5/2/2017	5:34	SM3113B	5/3/2017	19:57	2.18	<2.00	1	N	
22		P64736	South Jersey Water Test, LLC	08006	5/2/2017	5:35	SM3113B	5/3/2017	20:04	3.02	<2.00	1	N	
23		P64737	South Jersey Water Test, LLC	08006	5/2/2017	5:36	SM3113B	5/3/2017	20:11	<2.00	<2.00	1	N	
24		P64738	South Jersey Water Test, LLC	08006	5/2/2017	5:37	SM3113B	5/3/2017	20:17	52.7	<2.00	1	N	
25		P64739	South Jersey Water Test, LLC	08006	5/2/2017	5:38	SM3113B	5/3/2017	20:24	<2.00	<2.00	1	N	
26		P64740	South Jersey Water Test, LLC	08006	5/2/2017	5:39	SM3113B	5/3/2017	20:31	4.73	<2.00	1	N	
27		P64741	South Jersey Water Test, LLC	08006	5/2/2017	5:40	SM3113B	5/3/2017	20:37	<2.00	<2.00	1	N	
28		P64742	South Jersey Water Test, LLC	08006	5/2/2017	5:41	SM3113B	5/3/2017	20:44	2.05	<2.00	1	N	
29		P64743	South Jersey Water Test, LLC	08006	5/2/2017	5:42	SM3113B	5/3/2017	21:04	<2.00	<2.00	1	N	
30		P64744	South Jersey Water Test, LLC	08006	5/2/2017	5:43	SM3113B	5/3/2017	21:10	<2.00	<2.00	1	N	
31		P64745	South Jersey Water Test, LLC	08006	5/2/2017	5:44	SM3113B	5/3/2017	21:17	<2.00	<2.00	1	N	
32		P64746	South Jersey Water Test, LLC	08006	5/2/2017	5:45	SM3113B	5/3/2017	21:24	<2.00	<2.00	1	N	
33		P64747	South Jersey Water Test, LLC	08006	5/2/2017	5:46	SM3113B	5/3/2017	21:30	3.84	<2.00	1	N	
34		P64748	South Jersey Water Test, LLC	08006	5/2/2017	5:47	SM3113B	5/3/2017	21:37	3.63	<2.00	1	N	
35		P64749	South Jersey Water Test, LLC	08006	5/2/2017	5:48	SM3113B	5/3/2017	21:43	3.77	<2.00	1	N	
36		P64750	South Jersey Water Test, LLC	08006	5/2/2017	5:50	SM3113B	5/3/2017	21:50	<2.00	<2.00	1	N	
37		P64751	South Jersey Water Test, LLC	08006	5/2/2017	5:51	SM3113B	5/3/2017	21:56	<2.00	<2.00	1	N	
38		P64752	South Jersey Water Test, LLC	08006	5/2/2017	5:52	SM3113B	5/3/2017	22:03	<2.00	<2.00	1	N	
39		P64753	South Jersey Water Test, LLC	08006	5/2/2017	5:55	SM3113B	5/5/2017	11:11	35.0	<2.00	1	N	
40		P64754	South Jersey Water Test, LLC	08006	5/2/2017	5:56	SM3113B	5/5/2017	11:40	3.88	<2.00	1	N	

Arthur Rann School
Excel Template for Lead Results

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O
41	AR-WC10	N	P64755	South Jersey Water Test, LLC	08006	5/2/2017	5:57	SM3113B	5/5/2017	11:46	2.07	<2.00	1	N	
42	AR-WC11	N	P64756	South Jersey Water Test, LLC	08006	5/2/2017	5:58	SM3113B	5/5/2017	11:52	2.64	<2.00	1	N	
43	AR-WC12	N	P64757	South Jersey Water Test, LLC	08006	5/2/2017	6:00	SM3113B	5/5/2017	12:09	<2.00	<2.00	1	N	
44	AR-WC13	N	P64758	South Jersey Water Test, LLC	08006	5/2/2017	6:01	SM3113B	5/5/2017	12:14	<2.00	<2.00	1	N	
45	AR-WC6	N	P64759	South Jersey Water Test, LLC	08006	5/2/2017	6:03	SM3113B	5/5/2017	12:19	<2.00	<2.00	1	N	
46	AR-WC7	N	P64760	South Jersey Water Test, LLC	08006	5/2/2017	6:04	SM3113B	5/5/2017	12:25	<2.00	<2.00	1	N	
47	AR-WC8	N	P64761	South Jersey Water Test, LLC	08006	5/2/2017	6:05	SM3113B	5/5/2017	12:30	<2.00	<2.00	1	N	
48	AR-WF9	N	P64762	South Jersey Water Test, LLC	08006	5/2/2017	6:07	SM3113B	5/5/2017	12:36	53.1	<2.00	1	N	
49	AR-SK18	N	P64763	South Jersey Water Test, LLC	08006	5/2/2017	6:08	SM3113B	5/5/2017	12:42	10.8	<2.00	1	N	
50	AR-WF10	N	P64764	South Jersey Water Test, LLC	08006	5/2/2017	6:10	SM3113B	5/5/2017	12:48	35.0	<2.00	1	N	