

**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

Galloway Township Middle School

100 South Reeds Road
Galloway, NJ 08205


Results of Lead Analysis

Date & Time Sampled: 05/03/2017 05:08 - 06:40

Date & Time Analyzed: 05/05/2017 10:46 - 17:34

Sample Location	Sample Result	Action Level
Field Reagent Blank (FRB)	<2.00	15.5
GTMS-SK43	8.54	15.5
GTMS-WC3A	<2.00	15.5
GTMS-WC3B	<2.00	15.5
GTMS-SK44	8.51	15.5
GTMS-SK40	7.99	15.5
GTMS-WC2A	<2.00	15.5
GTMS-WC2B	<2.00	15.5
GTMS-SK39	<2.00	15.5
GTMS-SK1	2.52	15.5
GTMS-WC8	4.96	15.5
GTMS-SK7	5.25	15.5
GTMS-SK2	5.29	15.5
GTMS-WC10	<2.00	15.5
GTMS-SK4	<2.00	15.5
GTMS-WC9	<2.00	15.5
GTMS-IM1	<2.00	15.5
GTMS-SK3	2.72	15.5
GTMS-SK8	3.63	15.5
GTMS-SK9	2.27	15.5

Units - ug/L = ppb



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

Galloway Township Middle School

100 South Reeds Road
Galloway, NJ 08205


Results of Lead Analysis

Date & Time Sampled: 05/03/2017 05:08 - 06:40

Date & Time Analyzed: 05/05/2017 10:46 - 17:34

Sample Location	Sample Result	Action Level
GTMS-SK10	<2.00	15.5
GTMS-SK11	<2.00	15.5
GTMS-SK12	<2.00	15.5
GTMS-SK13	<2.00	15.5
GTMS-SK14	<2.00	15.5
GTMS-SK15	2.64	15.5
GTMS-SK16	4.62	15.5
GTMS-SK17	2.28	15.5
GTMS-SK18	<2.00	15.5
GTMS-SK19	3.54	15.5
GTMS-SK20	<2.00	15.5
GTMS-SK21	16.5	15.5
GTMS-SK22	<2.00	15.5
GTMS-SK23	4.19	15.5
GTMS-SK26	3.08	15.5
GTMS-SK25	<2.00	15.5
GTMS-SK24	<2.00	15.5
GTMS-SK27	3.05	15.5
GTMS-WC1A	<2.00	15.5
GTMS-WC1B	<2.00	15.5

Units - ug/L = ppb



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

Galloway Township Middle School

100 South Reeds Road
Galloway, NJ 08205


Results of Lead Analysis

Date & Time Sampled: 05/03/2017 05:08 - 06:40

Date & Time Analyzed: 05/05/2017 10:46 - 17:34

Sample Location	Sample Result	Action Level
GTMS-SK6	28.9	15.5
GTMS-SK5	8.75	15.5
GTMS-SK38	8.56	15.5
GTMS-SK42	6.63	15.5
GTMS-SK41	19.5	15.5
GTMS-WC6A	<2.00	15.5
GTMS-WC6B	<2.00	15.5
GTMS-SK37	23.4	15.5
GTMS-WC5A	<2.00	15.5
GTMS-WC5B	<2.00	15.5
GTMS-SK36	<2.00	15.5
GTMS-CM2	<2.00	15.5
GTMS-IM2	<2.00	15.5
GTMS-TK1	7.92	15.5
GTMS-SK33	6.01	15.5
GTMS-SK34	6.14	15.5
GTMS-SK32	10.2	15.5
GTMS-SK30	2.68	15.5
GTMS-SK29	5.48	15.5
GTMS-SK31	8.30	15.5

Units - ug/L = ppb



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

Galloway Township Middle School

100 South Reeds Road
Galloway, NJ 08205

Results of Lead Analysis

Date & Time Sampled: 05/03/2017 05:08 - 06:40

Date & Time Analyzed: 05/05/2017 10:46 - 17:34


Sample Location	Sample Result	Action Level
GTMS-SK35	<2.00	15.5
GTMS-WC7A	<2.00	15.5
GTMS-WC7B	<2.00	15.5
GTMS-WC4A	<2.00	15.5
GTMS-WC4B	<2.00	15.5

Units - ug/L = ppb

Action Level: The concentration of lead which determines whether some form of corrective action may be necessary.

QA/QC: Laboratory Fortified Blank (LFB) meets criteria of plus or minus 15% recovery.

Field Reagent Blank (FRB) concentration equals <2.00 ug/L.


Mark J. Riether, Laboratory Director

5/16/17
Date

CHAIN OF CUSTODY RECORD

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
www.sjwaterfrest.com
 NJ DEP Certification #08006

Customer: Galloway Township Public Schools
Contact: Steve Bolli
Address: 101 South Reeds Road
 Galloway, NJ 08205
Phone: **Fax:**
Office: (609) 748-1250 x 5121

Lab ID#	Sample Location	Collection Date	Collection Time	g/g	g/g	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
P6A783	Galloway Middle	5/3/17	508	X		D	1 x 250	HNO3*	First Draw Lead	
P6A784	GTMS - Field Blank		510	X		D	1 x 250	HNO3*	First Draw Lead	
P6A785	SK 43		512	X		D	1 x 250	HNO3*	First Draw Lead	
P6A786	WC3A		513	X		D	1 x 250	HNO3*	First Draw Lead	
P6A787	WC3B		514	X		D	1 x 250	HNO3*	First Draw Lead	
P6A788	SK 44		517	X		D	1 x 250	HNO3*	First Draw Lead	
P6A789	WC2A		519	X		D	1 x 250	HNO3*	First Draw Lead	
P6A790	WC2B		520	X		D	1 x 250	HNO3*	First Draw Lead	
P6A791	SK 39		521	X		D	1 x 250	HNO3*	First Draw Lead	
P6A792	SK 1		523	X		D	1 x 250	HNO3*	First Draw Lead	

MATRIX ABBREVIATIONS: D: DRINKING WATER A: AQUEOUS S: SOIL SL: SLUDGE GW: GROUND WATER SW: SURFACE WATER WW: WASTE WATER

Turnaround Time	Report Format	Comments/Special Instructions	Cooler Temp
<input type="checkbox"/> SJWT Standard is 10-20 work days <input type="checkbox"/> Rush turnaround available upon request and lab approval _____	<input type="checkbox"/> Standard <input type="checkbox"/> NJ DEP Reduced Deliverables <input type="checkbox"/> NJ DEP Full Deliverables <input type="checkbox"/> Electronic Data Deliverables <input type="checkbox"/> PWTA Format	* HNO3 preserved upon receipt at laboratory Yes _____ No _____	<input type="checkbox"/> _____ °C

Sampled by: <i>Justin Milla</i>	Received by: <i>[Signature]</i>	Date: 5/3/17	Time: 0830
Sampled by/Relinquished by: <i>[Signature]</i>	Received by: <i>[Signature]</i>	Date: _____	Time: _____
Relinquished by: <i>[Signature]</i>	Received by: <i>[Signature]</i>	Date: _____	Time: _____
Relinquished by: <i>[Signature]</i>	Received by: <i>[Signature]</i>	Date: _____	Time: _____

CHAIN OF CUSTODY RECORD

Customer: Galloway Township Public Schools
Contact: Steve Bolli
Address: 101 South Reeds Road
 Galloway, NJ 08205
Phone: Fax:
Office: (609) 748-1250 x 5121

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
 www.sjwatertest.com
 NJ DEP Certification #08006



Lab ID#	Sample Location	Collection Date	Time	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
PG4793	Galloway Middle GTMS - WCB	5/3/17	524	D	1 x 250	HNO3*	First Draw Lead	
PG4794	SK7		525	D	1 x 250	HNO3*	First Draw Lead	
PG4795	SK2		527	D	1 x 250	HNO3*	First Draw Lead	
PG4796	WCL0		528	D	1 x 250	HNO3*	First Draw Lead	
PG4797	SK4		530	D	1 x 250	HNO3*	First Draw Lead	
PG4798	WCB		531	D	1 x 250	HNO3*	First Draw Lead	
PG4799	FM1		533	D	1 x 250	HNO3*	First Draw Lead	
PG4800	SK3		534	D	1 x 250	HNO3*	First Draw Lead	
PG4801	SK8		535	D	1 x 250	HNO3*	First Draw Lead	
PG4802	SK9		536	D	1 x 250	HNO3*	First Draw Lead	

MATRIX ABBREVIATIONS: DIDRINKING WATER AQUEOUS SISOIL SL/SLUDGE GW/GROUND WATER SWS/SURFACE WATER WW/WASTE WATER

Turnaround Time ___ SJWT Standard is 10-20 work days ___ Rush turnaround available upon request and lab approval ___	Report Format ___ Standard ___ NJ DEP Reduced Deliverables ___ NJ DEP Full Deliverables ___ Electronic Data Deliverables ___ PWTA Format	Comments/Special Instructions ___ * HNO3 preserved upon receipt at laboratory ___ ___	Cooler Temp ___ °C Yes No
---	---	---	------------------------------------

Sampled by: *Justin Milillo*
 Sampled by/Relinquished by: *Justin Milillo* Date: 5/3/17 Time: 830 Date: 5/3/17 Time: 0830
 Relinquished by: _____ Date: _____ Date: _____
 Relinquished by: _____ Date: _____ Date: _____

CHAIN OF CUSTODY RECORD

Customer: Galloway Township Public Schools
Contact: Steve Bojli
Address: 101 South Reeds Road
 Galloway, NJ 08205
Phone: **Fax:**
Office: (609) 748-1250 x 5121

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
 www.sjwatertest.com
 NJ DEP Certification #08006



Lab ID#	Sample Location	Collection Date	Collection Time	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
P64803	Galloway Middle GTMS - SK10	5/3/17	537	D	1 x 250	HNO3*	First Draw Lead	
P64804	SK11		538	D	1 x 250	HNO3*	First Draw Lead	
P64805	SK12		539	D	1 x 250	HNO3*	First Draw Lead	
P64806	SK13		540	D	1 x 250	HNO3*	First Draw Lead	
P64807	SK14		541	D	1 x 250	HNO3*	First Draw Lead	
P64808	SK15		543	D	1 x 250	HNO3*	First Draw Lead	
P64809	SK16		544	D	1 x 250	HNO3*	First Draw Lead	
P64810	SK17		545	D	1 x 250	HNO3*	First Draw Lead	
P64811	SK18		547	D	1 x 250	HNO3*	First Draw Lead	
P64812	SK19		548	D	1 x 250	HNO3*	First Draw Lead	

MATRIX ABBREVIATIONS: D'DRINKING WATER A'AQUEOUS S'SOIL S'L/SLUDGE G'GWGROUND WATER S'WSURFACE WATER W'WASTE WATER

Turnaround Time SJWT Standard is 10-20 work days Rush turnaround available upon request and lab approval _____	Report Format Standard NJ DEP Reduced Deliverables NJ DEP Full Deliverables Electronic Data Deliverables PWTA Format	Comments/Special Instructions * HNO3 preserved upon receipt at laboratory	Cooler Temp °C
	Received by: _____ (Signature)		Date 5/3/17
Relinquished by: _____ (Signature)		Date _____	Time _____
Relinquished by: _____ (Signature)		Date _____	Time _____

Sampled by: *Justin Milillo*
 (Print)

Sampled by/Relinquished by: _____
 (Signature)

Relinquished by: _____
 (Signature)

Relinquished by: _____
 (Signature)

Date: 5/3/17
 Time: 830

Date: _____
 Time: _____

Date: _____
 Time: _____

Date: 5/3/17
 Time: 0830

Date: _____
 Time: _____

Date: _____
 Time: _____

CHAIN OF CUSTODY RECORD

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
 www.sjwatertest.com
 NJ DEP Certification #08006

Customer: Galloway Township Public Schools
Contact: Steve Bolli
Address: 101 South Reeds Road
 Galloway, NJ 08205
Phone:
Office: (609) 748-1250 x 5121

Lab ID#	Sample Location	Collection Date	Time	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
P64813	Galloway Middle GTMS - 5K20	5/3/17	549	D	1 x 250	HNO3*	First Draw Lead	
P64814	SK21		550	D	1 x 250	HNO3*	First Draw Lead	
P64815	SK22		551	D	1 x 250	HNO3*	First Draw Lead	
P64816	SK23		552	D	1 x 250	HNO3*	First Draw Lead	
P64817	SK26		555	D	1 x 250	HNO3*	First Draw Lead	
P64818	SK25		556	D	1 x 250	HNO3*	First Draw Lead	
P64819	SK24		557	D	1 x 250	HNO3*	First Draw Lead	
P64820	SK27		558	D	1 x 250	HNO3*	First Draw Lead	
P64821	WC1A		559	D	1 x 250	HNO3*	First Draw Lead	
P64822	WC1B		600	D	1 x 250	HNO3*	First Draw Lead	

MATRIX ABBREVIATIONS: D: DRINKING WATER A: AQUEOUS S: SOIL SL: SLUDGE GW: GROUND WATER SW: SURFACE WATER WW: WASTE WATER

Turnaround Time SJWT Standard is 10-20 work days Rush turnaround available upon request and lab approval _____	Report Format Standard _____ NJ DEP Reduced Deliverables _____ NJ DEP Full Deliverables _____ Electronic Data Deliverables _____ PWTA Format _____	Comments/Special Instructions * HNO3 preserved upon receipt at laboratory	Cooler Temp _____ °C
	Properly Preserved Yes _____ No _____		

Sampled by: *Justin Millilo*
 (Print)
 Sampled by/Relinquished by: *Justin Millilo*
 (Signature) Date: 5/3/17 Time: 830
 Relinquished by: _____
 (Signature) Date: _____ Time: _____
 Relinquished by: _____
 (Signature) Date: _____ Time: _____

Received by: _____
 (Signature) Date: 5/3/17 Time: 0830
 Received by: _____
 (Signature) Date: _____ Time: _____
 Received by: _____
 (Signature) Date: _____ Time: _____

CHAIN OF CUSTODY RECORD

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
 www.sjwatertest.com
 NJ DEP Certification #08006

Customer: Galloway Township Public Schools
Contact: Steve Bolli
Address: 101 South Reeds Road
 Galloway, NJ 08205
Phone:
Office: (609) 748-1250 x 5121

Lab ID#	Sample Location	Collection Date	Time	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
P64823	Galloway Middle	5/3/17	601	D	1 x 250	HNO3*	First Draw Lead	
P64824	SK5		602	D	1 x 250	HNO3*	First Draw Lead	
P64825	SK38		604	D	1 x 250	HNO3*	First Draw Lead	
P64826	SK42		610	D	1 x 250	HNO3*	First Draw Lead	
P64827	SK41		612	D	1 x 250	HNO3*	First Draw Lead	
P64828	WC6A		613	D	1 x 250	HNO3*	First Draw Lead	
P64829	WC6B		614	D	1 x 250	HNO3*	First Draw Lead	
P64830	SK37		615	D	1 x 250	HNO3*	First Draw Lead	
P64831	WC5A		617	D	1 x 250	HNO3*	First Draw Lead	
P64832	WC5B		618	D	1 x 250	HNO3*	First Draw Lead	

MATRIX ABBREVIATIONS: D: DRINKING WATER A: AQUEOUS S: SOIL SL: SLUDGE GW: GROUND WATER SW: SURFACE WATER WW: WASTE WATER

Turnaround Time	Report Format	Comments/Special Instructions	Cooler Temp
<input type="checkbox"/> Standard <input type="checkbox"/> NJ DEP Reduced Deliverables <input type="checkbox"/> NJ DEP Full Deliverables <input type="checkbox"/> Electronic Data Deliverables <input type="checkbox"/> PWTA Format	<input type="checkbox"/> * HNO3 preserved upon receipt at laboratory <input type="checkbox"/> Yes <input type="checkbox"/> No		°C

Sampled by: Justin Milla
 (Print)
 Sampled by/Relinquished by: Justin Milla
 (Signature) Date: 5/3/17 Time: 830
 Relinquished by: _____ Date: _____ Time: _____
 (Signature)
 Relinquished by: _____ Date: _____ Time: _____
 (Signature)

Received by: _____ Date: 5/3/17 Time: 0830
 (Signature)
 Received by: _____ Date: _____ Time: _____
 (Signature)
 Received by: _____ Date: _____ Time: _____
 (Signature)

CHAIN OF CUSTODY RECORD

Customer: Galloway Township Public Schools
Contact: Steve Bolli
Address: 101 South Reeds Road
 Galloway, NJ 08205
Phone: Fax:
Office: (609) 748-1250 x 5121

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
 www.sjwatertest.com
 NJ DEP Certification #08006



Lab ID#	Sample Location	Collection Date	Time	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
P64833	Galloway Middle GTMS - SK36	5/3/17	620	D	1 x 250	HNO3*	First Draw Lead	
P64834	CM2		621	D	1 x 250	HNO3*	First Draw Lead	
P64835	FM2		623	D	1 x 250	HNO3*	First Draw Lead	
P64836	TK1		625	D	1 x 250	HNO3*	First Draw Lead	
P64837	SK33		626	D	1 x 250	HNO3*	First Draw Lead	
P64838	SK34		627	D	1 x 250	HNO3*	First Draw Lead	
P64839	SK32		628	D	1 x 250	HNO3*	First Draw Lead	
P64840	SK30		629	D	1 x 250	HNO3*	First Draw Lead	
P64841	SK29		630	D	1 x 250	HNO3*	First Draw Lead	
P64842	SK31		632	D	1 x 250	HNO3*	First Draw Lead	

MATRIX ABBREVIATIONS: DIDRINKING WATER AQUEOUS SISOIL SL/SLUDGE GWGROUND WATER SWSURFACE WATER WWWASTE WATER

Turnaround Time SJWT Standard is 10-20 work days Rush turnaround available upon request and lab approval _____	Report Format Standard NJ DEP Reduced Deliverables NJ DEP Full Deliverables Electronic Data Deliverables PWTA Format	Comments/Special Instructions * HNO3 preserved upon receipt at laboratory	Cooler Temp °C
	Yes	No	Properly Preserved

Sampled by: *Justin M. Lillo*

Sampled by/Relinquished by: *Justin M. Lillo*

Relinquished by: _____

Relinquished by: _____

Received by: <i>(Signature)</i>	Date: 5/3/17	Time: 0830
Received by: <i>(Signature)</i>	Date:	Time:
Received by: <i>(Signature)</i>	Date:	Time:

CHAIN OF CUSTODY RECORD

Customer: Galloway Township Public Schools
Contact: Steve Bolli
Address: 101 South Reeds Road
 Galloway, NJ 08205
Phone: Fax:
Office: (609) 748-1250 x 5121

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
 www.sjwatertest.com
 NJ DEP Certification #08006



Lab ID#	Sample Location	Collection Date	Time	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
P64843	Galloway Middle GTMS - 5K35	5/3/17	634	D	1 x 250	HNO3*	First Draw Lead	
P64844	W67A		636	D	1 x 250	HNO3*	First Draw Lead	
P64845	W67B		637	D	1 x 250	HNO3*	First Draw Lead	
P64846	W64A		639	D	1 x 250	HNO3*	First Draw Lead	
P64847	W64B		640	D	1 x 250	HNO3*	First Draw Lead	
---				D	1 x 250	HNO3*	First Draw Lead	
---				D	1 x 250	HNO3*	First Draw Lead	
---				D	1 x 250	HNO3*	First Draw Lead	
---				D	1 x 250	HNO3*	First Draw Lead	

MATRIX ABBREVIATIONS: DIDRINKING WATER AQAQUEOUS SISOIL SLI SLUDGE GWGROUND WATER SWMSURFACE WATER WWWASTE WATER

Turnaround Time ___ SJWT Standard is 10-20 work days ___ Rush turnaround available upon request and lab approval _____	Report Format ___ Standard ___ NJ DEP Reduced Deliverables ___ NJ DEP Full Deliverables ___ Electronic Data Deliverables ___ PWTA Format	Comments/Special Instructions * HNO3 preserved upon receipt at laboratory	Cooler Temp °C
	Yes		No

Sampled by: Justin Milla
Sampled by/Relinquished by: Justin Milla
Relinquished by: Justin Milla
Relinquished by: Justin Milla

Date	Time	Received by:	Date	Time
5/3/17	830	(Signature)	5/3/17	0830
Date	Time	Received by:	Date	Time
		(Signature)		
Date	Time	Received by:	Date	Time
		(Signature)		

Galloway Township Middle School
Excel Template for Lead Results

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O
	Field ID	Flushed Y/N	Laboratory Sample ID	Laboratory Name	Lab Certification ID	Date Sampled	Time Sampled	Analytical Method	Date of Analysis	Time of Analysis	Concentration In ug/L	Reporting Limit (ug/L)	Dilution Factor	Digested (Y/N)	Qualifier
1															
2	Field Reagent Blank (FRB)	N	P64783	South Jersey Water Test, LLC	08006	5/3/2017	5:08	SM3113B	5/5/2017	13:45	<2.00	<2.00	1	N	
3	GTMS-SK3	N	P64784	South Jersey Water Test, LLC	08006	5/3/2017	5:10	SM3113B	5/5/2017	14:08	8.54	<2.00	1	N	
4	GTMS-WC3A	N	P64785	South Jersey Water Test, LLC	08006	5/3/2017	5:12	SM3113B	5/5/2017	14:14	<2.00	<2.00	1	N	
5	GTMS-WC3B	N	P64786	South Jersey Water Test, LLC	08006	5/3/2017	5:13	SM3113B	5/5/2017	14:30	<2.00	<2.00	1	N	
6	GTMS-SK4	N	P64787	South Jersey Water Test, LLC	08006	5/3/2017	5:14	SM3113B	5/5/2017	14:36	8.51	<2.00	1	N	
7	GTMS-SK40	N	P64788	South Jersey Water Test, LLC	08006	5/3/2017	5:17	SM3113B	5/5/2017	14:42	7.99	<2.00	1	N	
8	GTMS-WC2A	N	P64789	South Jersey Water Test, LLC	08006	5/3/2017	5:19	SM3113B	5/5/2017	14:48	<2.00	<2.00	1	N	
9	GTMS-WC2B	N	P64790	South Jersey Water Test, LLC	08006	5/3/2017	5:20	SM3113B	5/5/2017	14:53	<2.00	<2.00	1	N	
10	GTMS-SK39	N	P64791	South Jersey Water Test, LLC	08006	5/3/2017	5:21	SM3113B	5/5/2017	15:02	<2.00	<2.00	1	N	
11	GTMS-SK1	N	P64792	South Jersey Water Test, LLC	08006	5/3/2017	5:23	SM3113B	5/5/2017	15:08	2.52	<2.00	1	N	
12	GTMS-WC8	N	P64793	South Jersey Water Test, LLC	08006	5/3/2017	5:24	SM3113B	5/5/2017	15:13	4.96	<2.00	1	N	
13	GTMS-SK7	N	P64794	South Jersey Water Test, LLC	08006	5/3/2017	5:25	SM3113B	5/5/2017	15:19	5.25	<2.00	1	N	
14	GTMS-SK2	N	P64795	South Jersey Water Test, LLC	08006	5/3/2017	5:27	SM3113B	5/5/2017	15:24	5.29	<2.00	1	N	
15	GTMS-WC10	N	P64796	South Jersey Water Test, LLC	08006	5/3/2017	5:28	SM3113B	5/5/2017	15:41	<2.00	<2.00	1	N	
16	GTMS-SK4	N	P64797	South Jersey Water Test, LLC	08006	5/3/2017	5:30	SM3113B	5/5/2017	15:47	<2.00	<2.00	1	N	
17	GTMS-WC9	N	P64798	South Jersey Water Test, LLC	08006	5/3/2017	5:31	SM3113B	5/5/2017	15:52	<2.00	<2.00	1	N	
18	GTMS-IM1	N	P64799	South Jersey Water Test, LLC	08006	5/3/2017	5:33	SM3113B	5/5/2017	15:58	<2.00	<2.00	1	N	
19	GTMS-SK3	N	P64800	South Jersey Water Test, LLC	08006	5/3/2017	5:34	SM3113B	5/5/2017	16:19	2.72	<2.00	1	N	
20	GTMS-SK8	N	P64801	South Jersey Water Test, LLC	08006	5/3/2017	5:35	SM3113B	5/5/2017	16:24	3.63	<2.00	1	N	
21	GTMS-SK9	N	P64802	South Jersey Water Test, LLC	08006	5/3/2017	5:36	SM3113B	5/5/2017	16:30	2.27	<2.00	1	N	
22	GTMS-SK10	N	P64803	South Jersey Water Test, LLC	08006	5/3/2017	5:37	SM3113B	5/5/2017	16:36	<2.00	<2.00	1	N	
23	GTMS-SK11	N	P64804	South Jersey Water Test, LLC	08006	5/3/2017	5:38	SM3113B	5/5/2017	10:46	<2.00	<2.00	1	N	
24	GTMS-SK12	N	P64805	South Jersey Water Test, LLC	08006	5/3/2017	5:39	SM3113B	5/5/2017	11:05	<2.00	<2.00	1	N	
25	GTMS-SK13	N	P64806	South Jersey Water Test, LLC	08006	5/3/2017	5:40	SM3113B	5/5/2017	11:12	<2.00	<2.00	1	N	
26	GTMS-SK14	N	P64807	South Jersey Water Test, LLC	08006	5/3/2017	5:41	SM3113B	5/5/2017	11:38	<2.00	<2.00	1	N	
27	GTMS-SK15	N	P64808	South Jersey Water Test, LLC	08006	5/3/2017	5:43	SM3113B	5/5/2017	11:45	2.64	<2.00	1	N	
28	GTMS-SK16	N	P64809	South Jersey Water Test, LLC	08006	5/3/2017	5:44	SM3113B	5/5/2017	12:05	4.62	<2.00	1	N	
29	GTMS-SK17	N	P64810	South Jersey Water Test, LLC	08006	5/3/2017	5:45	SM3113B	5/5/2017	12:11	2.28	<2.00	1	N	
30	GTMS-SK18	N	P64811	South Jersey Water Test, LLC	08006	5/3/2017	5:47	SM3113B	5/5/2017	12:18	<2.00	<2.00	1	N	
31	GTMS-SK19	N	P64812	South Jersey Water Test, LLC	08006	5/3/2017	5:48	SM3113B	5/5/2017	12:24	3.54	<2.00	1	N	
32	GTMS-SK20	N	P64813	South Jersey Water Test, LLC	08006	5/3/2017	5:49	SM3113B	5/5/2017	12:31	<2.00	<2.00	1	N	
33	GTMS-SK21	N	P64814	South Jersey Water Test, LLC	08006	5/3/2017	5:50	SM3113B	5/5/2017	12:37	16.5	<2.00	1	N	
34	GTMS-SK22	N	P64815	South Jersey Water Test, LLC	08006	5/3/2017	5:51	SM3113B	5/5/2017	12:44	4.19	<2.00	1	N	
35	GTMS-SK23	N	P64816	South Jersey Water Test, LLC	08006	5/3/2017	5:52	SM3113B	5/5/2017	12:51	<2.00	<2.00	1	N	
36	GTMS-SK26	N	P64817	South Jersey Water Test, LLC	08006	5/3/2017	5:55	SM3113B	5/5/2017	12:57	3.08	<2.00	1	N	
37	GTMS-SK25	N	P64818	South Jersey Water Test, LLC	08006	5/3/2017	5:56	SM3113B	5/5/2017	13:04	<2.00	<2.00	1	N	
38	GTMS-SK24	N	P64819	South Jersey Water Test, LLC	08006	5/3/2017	5:57	SM3113B	5/5/2017	13:24	<2.00	<2.00	1	N	
39	GTMS-SK27	N	P64820	South Jersey Water Test, LLC	08006	5/3/2017	5:58	SM3113B	5/5/2017	13:30	3.05	<2.00	1	N	
40	GTMS-WC1A	N	P64821	South Jersey Water Test, LLC	08006	5/3/2017	5:59	SM3113B	5/5/2017	13:37	<2.00	<2.00	1	N	

Galloway Township Middle School
Excel Template for Lead Results

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O
41	GTMS-WC1B	N	P64822	South Jersey Water Test, LLC	08006	5/3/2017	6:00	SM3113B	5/5/2017	13:44	<2.00	<2.00	1	N	
42	GTMS-SK6	N	P64823	South Jersey Water Test, LLC	08006	5/3/2017	6:01	SM3113B	5/5/2017	13:50	28.9	<2.00	1	N	
43	GTMS-SK5	N	P64824	South Jersey Water Test, LLC	08006	5/3/2017	6:02	SM3113B	5/5/2017	13:57	8.75	<2.00	1	N	
44	GTMS-SK38	N	P64825	South Jersey Water Test, LLC	08006	5/3/2017	6:04	SM3113B	5/5/2017	14:16	8.56	<2.00	1	N	
45	GTMS-SK42	N	P64826	South Jersey Water Test, LLC	08006	5/3/2017	6:10	SM3113B	5/5/2017	14:23	6.63	<2.00	1	N	
46	GTMS-SK41	N	P64827	South Jersey Water Test, LLC	08006	5/3/2017	6:12	SM3113B	5/5/2017	14:42	19.5	<2.00	1	N	
47	GTMS-WC6A	N	P64828	South Jersey Water Test, LLC	08006	5/3/2017	6:13	SM3113B	5/5/2017	14:49	<2.00	<2.00	1	N	
48	GTMS-WC6B	N	P64829	South Jersey Water Test, LLC	08006	5/3/2017	6:14	SM3113B	5/5/2017	14:56	<2.00	<2.00	1	N	
49	GTMS-SK37	N	P64830	South Jersey Water Test, LLC	08006	5/3/2017	6:15	SM3113B	5/5/2017	15:02	23.4	<2.00	1	N	
50	GTMS-WC5A	N	P64831	South Jersey Water Test, LLC	08006	5/3/2017	6:17	SM3113B	5/5/2017	15:09	<2.00	<2.00	1	N	
51	GTMS-WC5B	N	P64832	South Jersey Water Test, LLC	08006	5/3/2017	6:18	SM3113B	5/5/2017	15:15	<2.00	<2.00	1	N	
52	GTMS-SK36	N	P64833	South Jersey Water Test, LLC	08006	5/3/2017	6:20	SM3113B	5/5/2017	15:22	<2.00	<2.00	1	N	
53	GTMS-CM2	N	P64834	South Jersey Water Test, LLC	08006	5/3/2017	6:21	SM3113B	5/5/2017	15:29	<2.00	<2.00	1	N	
54	GTMS-IM2	N	P64835	South Jersey Water Test, LLC	08006	5/3/2017	6:23	SM3113B	5/5/2017	15:35	<2.00	<2.00	1	N	
55	GTMS-TK1	N	P64836	South Jersey Water Test, LLC	08006	5/3/2017	6:25	SM3113B	5/5/2017	15:42	7.92	<2.00	1	N	
56	GTMS-SK33	N	P64837	South Jersey Water Test, LLC	08006	5/3/2017	6:26	SM3113B	5/5/2017	16:02	6.01	<2.00	1	N	
57	GTMS-SK34	N	P64838	South Jersey Water Test, LLC	08006	5/3/2017	6:27	SM3113B	5/5/2017	16:09	6.14	<2.00	1	N	
58	GTMS-SK32	N	P64839	South Jersey Water Test, LLC	08006	5/3/2017	6:28	SM3113B	5/5/2017	16:15	10.2	<2.00	1	N	
59	GTMS-SK30	N	P64840	South Jersey Water Test, LLC	08006	5/3/2017	6:29	SM3113B	5/5/2017	16:22	2.68	<2.00	1	N	
60	GTMS-SK29	N	P64841	South Jersey Water Test, LLC	08006	5/3/2017	6:30	SM3113B	5/5/2017	16:29	5.48	<2.00	1	N	
61	GTMS-SK31	N	P64842	South Jersey Water Test, LLC	08006	5/3/2017	6:32	SM3113B	5/5/2017	16:35	8.30	<2.00	1	N	
62	GTMS-SK35	N	P64843	South Jersey Water Test, LLC	08006	5/3/2017	6:34	SM3113B	5/5/2017	16:42	<2.00	<2.00	1	N	
63	GTMS-WC7A	N	P64844	South Jersey Water Test, LLC	08006	5/3/2017	6:36	SM3113B	5/5/2017	16:48	<2.00	<2.00	1	N	
64	GTMS-WC7B	N	P64845	South Jersey Water Test, LLC	08006	5/3/2017	6:37	SM3113B	5/5/2017	17:21	<2.00	<2.00	1	N	
65	GTMS-WC4A	N	P64846	South Jersey Water Test, LLC	08006	5/3/2017	6:39	SM3113B	5/5/2017	17:28	<2.00	<2.00	1	N	
66	GTMS-WC4B	N	P64847	South Jersey Water Test, LLC	08006	5/3/2017	6:40	SM3113B	5/5/2017	17:34	<2.00	<2.00	1	N	